



# Stop Light Report



**Yes**


Literature Displays in Exam Rooms
Wall Mounts for PCs in Exam Rooms
Have Upper Cabinets that are lockable in exam rooms
Vinyl Chairs - Reception and Exam Room
Bariatric Chairs
New TV - More Channels - Informational Channel
New Coffee Pot
Replace Blinds
More Electrical Outlets
More Locked Storage in Nurse's Office
Cabinets and Counterspace in Lab
Less Sinks in Lab (Leave Only 1)
5 Legged Stools for Pap Smears (4)
New Office Furniture (Desks, Chairs)
Wall Painted Blue for Derm
Tinted Windows for Reception Area and Conference Room
Chair Rails
Wall Mounted Display Case in Reception Area
Eliminate Counters in Exam Rooms
Bariatric Lab Chair



**Maybe**

X-Ray Machine Config Changes - Haffner X-Ray – *Awaiting Word from Haffner to see if this is possible*

More Printers – *Awaiting Word from Indy VAMC OIT to see if more printers are available.*



**We cannot do now and here is why.**

Change Door Swings – <i>Privacy Curtains Makes This Obsolete</i>
Ceiling Computer Mount – <i>Ceiling cannot support the weight of computer and monitor</i>
X-Ray Pt Sitting Area – <i>Having a sitting area would block the exit and would put the facility in violation of code.</i>